



**2020/2021 Anglian Water in Hartlepool Hire Application for a  
Metered Standpipe & 3 Piece Calm Network Key**



Please complete all sections below. If you have any queries please contact Aquam Water Services Ltd on 03300 94 03 24 or E-Mail us on [hartlepool@aquamcorp.co.uk](mailto:hartlepool@aquamcorp.co.uk). On completion of the application form post to: Aquam Water Services Ltd, 5 Astoria Court, Tom Dando Close, Normanton, WF6 1TP. Or E-mail to: [hartlepool@aquamcorp.co.uk](mailto:hartlepool@aquamcorp.co.uk).

Please tick one of the following boxes: Existing Account Holder  New Account Applicant

Please ensure you have forwarded your Credit Account Application. Please note if you are set up as a Cash Hire Customer a £300.00 Deposit will be required in advance of your Standpipe Hire Date. This Deposit will be taken via WorldPay; therefore an email address will be required in the section below.

**1. Applicant**

Company Name..... Contact Name.....  
 Invoice Address..... Telephone .....  
 ..... Mobile .....  
 ..... Email Address.....  
 ..... Post Code..... Account Number ..... (If Known)  
 Accounts Landline ..... Accounts Email .....

**2. Information**

Purpose for which the water is required ..... Please Deliver to the Site Address  £25.00  
 ..... We wish to collect from your Normanton Depot   
 Site Address..... Dates Required: From: .....  
 ..... To: .....  
 ..... Post Code: ..... **Please note you will need to contact the Office prior to your requested collection date to arrange the Off hire.**  
 Site Contact Name ..... Please indicate if you need the outlet fitting to be changed on the 22mm Standpipe to:  
 Contact No: ..... 19mm Hose Tail  Claw  2" Female Instantaneous   
 Contact Email: ..... We require the following Additional Equipment:  
**Purchase Order Number** .....  Hose .....Meters (Sale Item based on £ per Meter)  
 Type –  Black Contractors  1" Lay flat  2" Lay flat  
 Hose Connectors (Charge is based upon type of connector)  
 Sterilisation Fluid in Spray Bottle (Sale £2.00 + VAT)  
 Chlorine Tablets (1 Tub = 30 Tablets. Sale £8.60 + VAT)  
 Standpipe Heavy Duty Carry Bag  (£2.00 Per Week)  
 (Sale £75.00)

**3. Charges** - Please indicate which size standpipe & hire period you require.

<b>22mm Metered Standpipe (tap outlet)</b>	<b>40mm Metered Standpipe (Fire Hose)</b>
£32.00 per week <input type="checkbox"/>	£54.00 per week <input type="checkbox"/>
22mm Metered Standpipe Annual Paid in Advance	40mm Metered Standpipe Annual Paid in Advance
£910.00 <input type="checkbox"/>	£1200.00 <input type="checkbox"/>
22mm Metered Standpipe Six Months Paid in Advance	40mm Metered Standpipe Six Month Paid in Advance
£525.00 <input type="checkbox"/>	£700.00 <input type="checkbox"/>

Water = £1.3107 + Vat per Cubic Meter (1000 Litres = 1 Cubic Meter)

**4. Agreement**

I hereby make application to use a metered standpipe in the Yorkshire Water Region for the purpose as indicated above. I have read and accept the Terms & Conditions overleaf. I understand that I can only use a Metered Standpipe provided by Aquam Water Services Limited and attach it to a wash out (WO). I accept that this does NOT permit the use of any Fire Hydrant (FH). A breach of the terms & conditions could lead to a criminal prosecution.

Signature ..... Print Name ..... Date .....

For and on behalf of (Company) ..... FO 052 v2 April 19

# TERMS AND CONDITIONS FOR THE USE OF STANDPIPES

1. Under no circumstances shall a Metered Standpipe be used on any hydrant marked as a 'fire hydrant' (FH)

2. The Metered Standpipe will be no larger than 40mm in diameter. The size of Standpipe will be agreed at point of Licence Application.

3. Standpipes used to take water from wash out (WO) hydrants must be to Anglian Water specification and can only be provided by Water Services (Aquam). Any standpipe in use that has not been obtained from Water Services and is therefore not an approved Standpipe, will be deemed as use without consent and further action will be taken as referred to in paragraph 16 (iii) below.

4. Any party found to have been tampering with the Metered Standpipe in any way, will be subject to further action including the immediate withdrawal of the standpipe without a refund of the fee.

5. Each registered Standpipe will be fitted with a backflow prevention device in the form of a BS6282 double check valve.

6. Standpipes and attached equipment must be kept in a clean, well-maintained condition. All Standpipes and attached equipment must be properly maintained in order to minimise the risk of contamination, backflow and water leakage. Damaged and worn equipment must not be used. You may be required to show Anglian Water your schemes of ensuring Standpipes are disinfected prior to use.

7. Water taken from a wash out hydrant must not be used for drinking or food preparation and should not be allowed to run to waste.

8. The user shall be responsible for the cost of repair of any damage caused to the wash out hydrant or associated apparatus while connecting, using or disconnecting the Standpipe.

9. The user shall comply with requirements of the New Roads and Street Works Act 1991 and any requirements of the high- way authority when using a Standpipe on a wash out hydrant in a street.

10. Anglian Water will not accept liability in respect of any loss or damage caused to the property of any person or persons wherever situate by reason of the use or operation of the wash out hydrant or Standpipe, or in respect of any injury suffered by any person or persons by reason of the use or operation of the wash out hydrant, Standpipe.

The user, by signing the "Application for a Metered Standpipe" form, agrees to indemnify Anglian Water against all actions, claims, damages, or demands which may result in respect of any such loss, damage, or injury.

11. Anglian Water and any Fire Authority retain the right to remove any Standpipe or asset from the water network at any time and for any purpose. Anglian Water

will not be liable for compensation claims in relation to a loss of use of supply following the removal of the apparatus.

12. Where a Standpipe(s) is being used on the same site for more than one month, the customer is required to apply for a temporary or permanent metered supply for that site.

13. Any breach of these terms and conditions may result in action being taken against the Agreement holder irrespective of who was operating the Standpipe at the time of the breach. It is the Agreement holder's responsibility to ensure that the terms and conditions are complied with at all times. Metered Standpipes cannot be sublet to other companies or contractors. If a metered Standpipe is found to have been sublet to a third party, action will be taken, where necessary, against the Agreement holder only who has agreed and accepted these terms and conditions.

14. Metered Standpipes contain a line strainer (filter) which must be maintained and kept clean. The hirer and operator of the Standpipe will be liable for any costs incurred to Water Services as a result of damage to the metered Standpipe or hydrant.

15. Anglian Water reserves the right to

- (i) Instruct the user not to use any specific wash out hydrant.
- (ii) Terminate any contract or agreement should the user be in breach of any of these terms and conditions
- (iii) Instigate prosecution proceedings pursuant to Section 174(3) of the Water Industry Act 1991 in respect of water taken in contravention of these terms and conditions, the Water Regulations or any drought orders that may be imposed. Anglian Water reserves their rights in full to take any such action; and
- (iv) Audit company vehicles using Anglian Water wash out hydrants to ensure all terms and conditions are met.

## Operating Hydrants

### When attaching a Standpipe

- Clean out the hydrant pit of any debris
- Spray the hydrant and standpipe with approved chlorine-based spray solution
- Do not apply any bending or sideways load to the Standpipe
- Operate the spindle at arm's length
- Always open and close the hydrant in a slow and controlled manner
- Flush the hydrant to clear the connection point
- Do not cross thread the outlet
- Visually inspect the Standpipe to confirm it is fitted correctly
- Do not stand directly over the hydrant
- If any hydrant fails in operation, please report to Water Services immediately